Test Report Specifications
Ultra/6000 DH

ANSI/AMAA/NWWDA 101/I.S-97
Report # 57194.02-701-47
NAMI Certificate NI0015006

Summary of Results

Title	Specimen 2
Rating	***DP H-R25*** 44 x 60
Operating Force	24 lbs max
Air Infiltration	0.08 cfm/ft^2
Water Resistance Pressure	6.00 psf
Uniform Deflection Pressure	625.0 psf
Uniform Structural Pressure	637.5 psf
Deglazing	Passed
Forced Entry Resistance	Grade 10

NFRC 100-2014/200-2014/500-2014
Report # G8982.01-116-45

Base Unit Validated 47.25” x 59.00”	
Simulated Thermal Transmittance (U-Factor)	0.30

Specific Thermal Results

6000 Ultra Double Hung								
Spacer Type	Super Spacer with Argon						*Specifically for the Northern Climate Zone*	
LoE Type	E-Max* (LoE^2)		Advanced E-Max (LoE^3)		E-Max* (LoE^3) & I-89		LoE 180 & I-89	
	No Grids	Grids	No Grids	Grids	No Grids	Grids	No Grids	Grids
U-Factor	*0.29*	*0.29*	*0.29*	*0.29*	*0.25*	*0.25*	*0.26*	*N/A*
SHGC	*0.28*	*0.25*	*0.21*	*0.19*	*0.20*	*0.18*	*0.48*	*N/A*
VT	0.52	0.46	0.48	0.42	0.47	0.41	0.45	*N/A*
CR	54	54	55	55	44	44	42	*N/A*

Updated 1/12/2026